



ROOFLIGHT APPLICATION GUIDE

Single skin rooflight for use with single skin profile metal roof systems

Typical Cross Section



Typical End Laps and Intermediate Purlins



Recommended Sheet Types

Filon sheet type	Non-fragility classification to ACR[M]001	Expected period of non-fragility ⁽¹⁾	Recommended frequency of roof access	Recommended purlin spans
CE30E	B	5 to 20 years ⁽²⁾	Infrequent	1.35m to 2.0m
CEDR24E	B	5 to 20 years ⁽²⁾	Infrequent	1.35m to 2.0m
CE36E	B	25 years	Frequent	1.0m to 2.25m
CEDR30E	B	25 years	Frequent	1.0m to 2.25m
SUPASAFE E	B	30 years	Very frequent	0.6m to 2.5m

⁽¹⁾Note that the expected non-fragility period of rooflights is affected by all components used within the roof assembly and when a specific period of non-fragility is required all components used should have the same degree of durability as the rooflights. This would typically require the use of austenitic stainless steel fasteners and minimum Class A butyl mastic sealant, always consult the component manufacturer or supplier.

⁽²⁾Minimum specification, correctly installed rooflights are rated Class B non-fragile during the construction phase, when new, and for an expected period of 5 to 20 years depending on external factors as defined in the Rooflight Association guidance document NTD03.1.

Fire Performance

Filon Grade 300: B_{ROOF}(t4) to BS EN 13501 Part 5.

Filon Grade 104: B_{ROOF}(t4) to BS EN 13501 Part 5. TP(a) rating to BS 2782-0 Method 508A

Filon Grade 101: B_{ROOF}(t4) to BS EN 13501 Part 5. TP(a) rating to BS 2782-0 Method 508A

For further information, please refer to Filon Technical Information Sheet: TIS003 England
TIS003-1 Wales
TIS003-2 Scotland
TIS003-3 Northern Ireland

Typical Fixing Specification

Minimum roof pitch

In accordance with BS 5427: Code of practice for the use of profiled sheet for roof and wall cladding on buildings, Filon rooflights are suitable for a finished roof pitch of at least 4° (5.5° design pitch). For lower roof pitch solutions, please contact Filon Technical Department.

Main fasteners

Filon single skin rooflights should be secured to purlins with minimum 5.5mm diameter, self drill/tap austenitic stainless steel screws that incorporate minimum 29mm diameter sealing washers, typically coloured poppy red. Fasteners should be located in the profile troughs at maximum 200mm centres across the sheet at every purlin location.

End laps

Any end laps should be located directly over a purlin. The top edge of an underlapping rooflight should be minimum 50mm from the main fixing line. The leading edge of an overlapping rooflight is normally 100mm from the main fixing line. The end lap joints should be sealed with two continuous runs of 6mm x 5mm tape or 6mm bead cross-linked butyl mastic sealant. The sealant runs should be located within 10mm to 15mm on either side of the fixing line. An optional run of gun applied silicone to classification ISO 11600-F-25 LM may be applied 15mm from the leading edge of the overlapping sheet within the joint to provide a supplementary seal and prevent dirt ingress.

Side laps

The side lap joints should be stitched at maximum 450mm centres with expanding metal grommet type fasteners if the rooflight is overlapped by adjacent metal sheets or laps to another rooflight, but note that it is recommended for a rooflight to overlap the metal sheets on both sides whenever possible. Standard stitch screws may be used where a rooflight overlaps the adjacent metal sheet. On exposed sites or roof pitches below 10° the centres should be reduced to 300mm. The side lap joints should be sealed with minimum one run of 6mm x 5mm tape or 6mm bead cross-linked butyl mastic sealant located on the weather side of the stitch fasteners.

FILON[®]

FILON[®] Products Limited
Unit 3, Ring Road, Zone 2, Burntwood Business Park
Burntwood, Staffordshire WS7 3JQ, England

Tel: +44 (0)1543 687300 Email: sales@filon.co.uk

WWW.FILON.CO.UK

FILON[®] is a trademark of Filon Products Ltd.

Information and recommendations contained in this publication are given in good faith without warranty or guarantee. Because we are constantly seeking to improve our products we reserve the right to change specifications at any time. No liability can be accepted for any claims, losses or demands arising from the contents of this publication. This statement does not affect any statutory rights which cannot be excluded by agreement