

# Technical Information Sheet

## TIS003-1 Fire – Roof Application

### Wales

(July 2025)



Filon Products Ltd manufacture three Fire Grades to meet the requirements of The Building Regulations Wales 2010, Approved Document B, Fire safety: Volume 2 - Buildings Other Than Dwellinghouses.

Filon sheets are tested and classified in accordance with the following standards:

**BS EN 13501 Part 5** - Classification using data from external fire exposure to roofs tests.

**BS 2782-0 Annex B Method 508A** - Classification for TP(a) assessment rating of plastics.

**BS 476 Part 3** - Classification and method of test for external fire exposure to roofs.

**BS 476 Part 6** - Method of Test for Propagation of Products.

**BS 476 Part 7** - Method of test to determine the classification of the surface spread of flame of products.

Filon Fire Grades and test ratings are as follows:

**Filon Grade 300** - B<sub>ROOF</sub> (t4) to BS EN 13501 Part 5

SAB to BS 476 Part 3

Class 3 to BS 476 Part 7

**Filon Grade 104** - B<sub>ROOF</sub> (t4) to BS EN 13501 Part 5

TP(a) to BS 2782-0 Method 508A

SAA to BS 476 Part 3

Class 1 to BS 476 Part 7

**Filon Grade 101** - B<sub>ROOF</sub> t4) to BS EN 13501 Part 5

TP(a) to BS 2782-0 Method 508A

SAA to BS 476 Part 3

Class 1 to BS 476 Part 7

Class 0 to BS 476 Part 6

Our recommendations are provided in good faith, but approval from the appropriate local government authority may be required in certain circumstances or if there is any uncertainty regarding the correct material to use. The following references are taken from the above document.

### Internal Liners and Single Skin

Section B2 - Section 7: *Wall and ceiling linings*, provides classifications to BS EN 13501 Part 1 and BS 476 Part 7. Clause 7.1, Table 10: *Classification of linings*, lists the requirements for various building types and room size.

**Class 3 - Filon Grade 300** for rooms not more than 30m<sup>2</sup> in non-residential accommodation.

**Class 1 - Filon Grade 104** for other rooms including garages: Note that this covers the majority of industrial applications.

**Class 0 - Filon Grade 101** for a circulation space, subject to Building Control approval.

Please note that Building Control approval is strongly recommended for large area applications.

# Technical Information Sheet

## TIS003-1 Fire – Roof Application

### Wales

(July 2025)



There are limitations stated in Section 7 for a rooflight liner or single skin rooflight that is rated Class 3 and for certain thermoplastic rooflights, these restrictions do not apply to **Filon Grades 101 & 104**. Table 11, along with Diagrams 27 and 27A, outlines the criteria for using rooflights with a **Class 3** inner surface as follows:

Diagram 47 provides the same restrictions for rooflights with a Class D-s3,d2 or Class 3 inner surface as Diagram 27 in terms of area and space separation.

Each rooflight area or rooflight group must not exceed 5m<sup>2</sup> area. The minimum space separation in any direction between rooflight areas is 3m. For industrial and other non-residential purpose groups this may be reduced to a minimum of 1.8 metres, but the rooflights should be evenly distributed and not exceed 20% of the floor area of the room.

Note that GRP roof liners and single skin sheets **must not** be used within 1.5m of a compartment wall.

### External Roofs

Section B4 Section 15: *Roof Coverings*, provides classifications to BS EN 13501 Part 5 and BS 476 Part 3. Table 16, *Limitations on roof coverings*, lists the designation for a roof covering in relation to the minimum distance from any point on a relevant boundary.

Using the information listed in Table 16, the following recommendations apply:

There are no boundary restrictions on the use of **any** Filon Fire Grade roof covering, but the requirements for a liner still apply.

Table 17 provides guidance for the permissible use of rooflights having a Class 3 lower surface; therefore, **Filon Grade 300** may be used in following applications:

- A balcony, veranda, carport, covered way or loading bay, which has at least one longer side wholly or permanently open.
- Detached swimming pool.
- Conservatory, garage, or outbuilding, with a maximum floor area of 40m<sup>2</sup>.

### External Walls

Section B4 Section 13: *Construction of external walls*, lists the classifications for an external wall surface depending on building height and proximity to a relevant boundary.

Using the information in Diagram 40, the below recommendations for walls are based upon current requirements for industrial, storage and other non-residential buildings. It is strongly recommended that Building Control approval is sought if there is any concern or doubt regarding the correct use of materials.

| External Wall Surface  |                     |                     |
|------------------------|---------------------|---------------------|
| Distance From Boundary | Building Height     | Required Fire Grade |
| Less than 1m           | Less than 18m       | Filon Grade 101     |
| Less than 1m           | More than 18m       | Filon Grade 101     |
| More than 1m           | Less than 18m       | Filon Grade 300     |
| More than 1m           | Ground level to 18m | Filon Grade 104*    |
| More than 1m           | From 18m and over   | Filon Grade 101     |

\*In practical terms it would be prudent to use **Filon Grade 101** for the complete wall to ensure consistency of appearance and to reduce the risk of site error.